



No.DJB/QCLTYR/PD/260310

DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
TRANS YAMUNA REGION TAHIRPUR DELHI-110093



Licence No- CRO/QM/L-8004274-1 as per IS/ISO 9001:2015



एक कदम स्वच्छता की ओर

NO: DJB/ACWA(TYR)/2026.....

DATE:- 30-03-2026

Analysis report of water samples collected from (1) Inlet (DJB supply), (2) Outlet of LITTLE FLOWERS PUBLIC SR. SEC. SCHOOL, SHIVAJI PARK, BABARPUR ROAD, SHAHDARA, DELHI-110032 for drinking purpose.

Ref. No. – LFPS/18873/2026,
Challan No: - 291,

dated: - 02.03.2026
dated: - 16.03.2026

ACWA-TYR

Diary No. 1041 dt. 01.04.2026

Date of collection: 27.03.2026

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
A.	Physical Examination					
1.	Colour	...	...	-	CLEAR	CLEAR
2.	Odour	...	...	-	CHLOR.	CHLOR.
3.	Turbidity	1.0	5.0	NTU	1.46	1.70
4.	pH Value	6.5-8.5	--	-	7.4	7.4
5.	Electrical Conductivity	--	--	µs/cm	217	216
6.	Total Dissolved Solids	500	2000	mg/l	141	140
B.	Chemical Examination					
7.	P th Alkalinity	...	...	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	70	68
9.	Total Hardness	200	600	mg/l	92	92
10.	Calcium as (Ca)	75	200	mg/l	24.0	24.8
11.	Magnesium as (Mg)	30	100	mg/l	7.68	7.20
12.	Ammonical Nitrogen	0.5	NR	mg/l	N.D	N.D
13.	Nitrite	...	...	mg/l	N.D	N.D
14.	Nitrate	45	NR	mg/l	1.98	2.03
15.	Sulphate	200	400	mg/l	31.86	32.01
16.	Chloride	250	1000	mg/l	10	08
17.	Fluoride	1.0	1.5	mg/l	0.12	0.10
18.	Dissolved Iron	1.0	NR	mg/l	0.10	0.09
19.	Cyanide	0.05	NR	mg/l	N.D	N.D
20.	Residual Chlorine	0.2	1.0	mg/l	0.40	0.30
C.	Bacteriological Examination					
21.	Coliform count	Absent	NR	MPN/100ml	0	0

REMARKS:- On the basis of above tested parameters, both water samples conform to the prescribed limits and can be considered fit for drinking purpose.

(B. Sheikh Lal)

ACWA(TYR) Water Analyst

DJB, Govt. of N.C.T. of Delhi

Quality Control Zonal Laboratory (TYR)

Tahir Pur Dilshad Garden, Delhi-93

(A.G. Susmitha)

BACTERIOLOGIST

(Gulesh Jainar)

CHEMIST

(Mayank Yadav)

A/CHEMIST

MUNICIPAL COPORATION OF DELHI

PUBLIC HEALTH DEPARTMENT

SHAHDARA NORTH ZONE

No.DHO/Shah(N)/2025D-547

Dated 29/9/25

SCHOOL INSPECTION REPORT

In reference to your application duly submitted in the office of undersigned vide diary no. 552 dated 10.07.2025. the inspection of "LITTLE FLOWERS PUBLIC SR. SEC. SCHOOL" at Shivaji Park, Babarpur Road Shahdara, Delhi-110032 was carried out on dated 12.07.2025. During the inspection. It was found that the school is running under satisfactory sanitary & hygienic conditions. Provision of latrines & urinals is sufficient according to the number of students.

In view of the above findings, undersigned is hereby pleased to grant "PROVISIONAL NO OBJECTION CERTIFICATE FROM HEALTH POINT OF VIEW" to the above-said school. This certificate is valid for a period of one year from the date of issue.

**PRINCIPAL
LITTLE FLOWERS PUBLIC SR. SEC. SCHOOL
SHIVJI PARK, BABARPUR ROAD
SHAHDARA, DELHI-110032**


**Dy. Health Officer
Shahdara North Zone**
उप-स्वास्थ्य अधिकारी
शाहदरा उत्तरी क्षेत्र
दिल्ली नगर निगम